



Purchasing Department | Tel (860) 584-6195

Invitation to Bid 2C24-027
Bristol Landfill Erosion Repairs
Addendum 02
October 10, 2023

Please note the following questions and subsequent responses:

- Q01. Specs require no more than 10 psi for equipment utilized while traveling on the existing liner. Is that the pressure allowed at the liner surface or pressure at a certain depth of cover over the liner?
- A01. At the liner.
- Q02. Addendum 01 notes that the contractor shall remove the sediment from the existing swale around the northern limits. To clarify is that in the area of the repairs or the entire +/- 1700 lf of swale ?
- A02. Yes.
- Q03. Are we allowed to remove and replace the fence at the corner of the Covanta entrance and Lake Compounce road regarding area 8 / 9?
- A03. Yes.

All other terms and conditions remain unchanged.

A handwritten signature in blue ink that reads 'Roger D. Rousseau'.

Roger D. Rousseau
Purchasing Agent
rogerrousseau@bristolct.gov

RETURN THIS FORM IMMEDIATELY!

City of Bristol, Connecticut
Acknowledgment: Receipt of Bid Documents
Bid: 2C24-027
Title: Bristol Landfill Erosion Repair
Addendum 02

Please take a moment to acknowledge receipt of the attached documents. Your compliance with this request will help us to maintain proper follow-up procedures while ensuring that all recipients have the opportunity to submit proposals.

Date Addendum 02 was issued October 10, 2023
Date Addendum 02 was received ___/___/___
Do you plan to submit a bid? Yes ___ No ___

Print or type the following information:

Company name: _____
Address: _____
City or Town/Zip code: _____
Phone: _____
Email: _____
Received by: _____

Note: acknowledgments are requested!
purchasing@bristolct.gov